

DAYTON ELECTRIC DEPARTMENT

Requirements for Underground Electric Service: Residential

- Dayton Electric Department will spot the location of the meter base on customer building nearest to the source, plus 12' either side.
- Customer will install approved meter base for underground service.
- Customer will open ditch, install conduit, and upon inspection, close ditch.
- Customer will install conduit as specified 2 ½" for 200 amp service, 3" for 400 amp service, any conduit above ground must be schedule 80.
- Customer will install a pull string in the conduit.
- Communication cables may occupy ditch with power cable. There must be one (1) foot of fill dirt placed over power cable conduit before communication cable can be installed.
- After all requirements are met, DED will install underground service wire from pole to meter base.

